Figure 4.30

Eyewash station weekly check log

Eyewash stations require weekly checks to be compliant with the American National Standards Institute which OSHA may reference during an inspection. If your eyewash station does not have a weekly log already attached to the fixture, use this log to check the proper functioning of the station and to flush out stagnant water. Keep a separate log for each station and inspect for:

Access and signage. Eyewash stations must be easily identifiable and unobstructed.

Operation. Turn on the station and check that:

1. The stations activates easily with foot or one-handed control

2. Flow removes eyepiece covers

3. Water flows evenly, in a steady stream from both eyepieces

Flush. Run the station for three minutes to flush stagnant water from the line.

Eyepiece disinfection. Rinse eyepieces with 10% bleach solution, flush with water for 15 seconds, and replace eyepiece on deactivated station.

Date (weekly)	Access, signage	Operation	Flush	Eyepiece disinfection	Notes	Initial